

## **Fire Hydrant 6"**

### **Qualified Product List      Specification - Requirements**

ODOT Construction and Materials Specifications 748.15

### **Requirements for inclusion on the Qualified Product List**

#### **Submit to the Office of Materials Management the following information:**

1. Manufacturer's letter certifying the 6 inch fire hydrants supplied to the project will meet or exceed Departmental specifications and include:
  - A Provide typical certified test data for the fire hydrants showing compliance to materials requirements and AWWA C502
  - B A notarized document that the fire hydrant meets the Domestic origin requirements of the Department's specifications
  - C Markings to be shown on each 6 inch fire hydrant
2. Agreement to immediately notify the Department on any changes in production, materials, dimensions, before shipment.
3. Provide the Department a contact name, number and e-mail address
4. Provide re-certification documentation by January 1 of each year

#### **Acceptance by the Department**

The Office of Materials Management will review a manufacturer's submittal for compliance with specification requirements.

Accepted products will be listed on the Department's qualified product list web page and will be loaded into the Department's Construction Management System for acceptance in the field through the QPL screen.

#### **Field Documentation requirements**

Products on the QPL will be accepted if they can be identified by the field to a supplier/manufacturer listed on the Department's Qualified Products List