

Ohio Department of Transportation

Prebid Questions

Project No. 100135

Sale Date - 3/11/2010

Question Submitted: 3/9/2010

Question Number: 1

on the covered bridge deck can a screed machine be used instead of bidwell due to limited access.

The answer to the question is contained in Supplemental Specification 847.09. If the "screed machine" is self-propelled and meets the above specifications, then it can be used. In addition, if it can be used on the Covered Bridge deck, it can also be used on the Campground Bridge deck.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.