

Ohio Department of Transportation Prebid Questions

Project No. 080430

Sale Date - 6/18/2008

Question Submitted: 6/3/2008

Question Number: 1

Addendum Number 6 under "Revise the following sheets:" - Revise Sheet 16 the second paragraph - Third Sentence states "As underdrains cannot be are to be excavated." Why can't the underdrains be placed before the geotextile fabric? Where does the Geotextile Fabric Type A go? Where is the underdrain located?

The note does not limit the contractor from placing the underdrains prior to placement of the geotextile fabric. As stated in the second sentence, "Place Geotextile Fabric on the bottom of the undercut" .

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.