

Ohio Department of Transportation

Prebid Questions

Project No. 060156

Sale Date - 3/22/2006

Question Submitted: 2/20/2006

Question Number: 1

Sheet 33/56 refers to Allan Block and Mirafi Geogrid. Are other equal segmental blocks and geogrids acceptable?

Allan Block that is referred to in question is included in Reference No. 84 - SPECIAL - RETAINING WALL, MISC.: MODULAR CONCRETE BLOCK UNITS, CONSTRUCTED and Reference No. 86 - SPECIAL - RETAINING WALL, MISC.: MODULAR CONCRETE BLOCK CAP UNITS which are described by Plan Notes on Sheets 5 and 6. The Modular Concrete Block Retaining Wall Units from the source stated by the note have been selected by the Village Administrator to meet the requirement of matching the existing natural limestone block wall. Allan Block or equal from other sources must be approved by the Village Administrator before they can be used in accordance with the Plan note. Mirafi Geogrid Soil Reinforcement that is referred to in question is included in Reference No. 88 - SPECIAL - GEOGRID which is described by Plan Note entitled ITEM SPECIAL 690.12020-GEOGRID- on Sheet 33. The minimum properties that an approved equal grid must meet are given in the Plan note.

Question Submitted: 3/10/2006

Question Number: 2

The pav't markings are listed as paint (642) in the proposal, but the plans call for Epoxy (646). Please advise.

Question Submitted: 3/10/2006

Question Number: 3

Bid item 12 608 4" Conc. Walk 5336.87 SF

The quantity does not take into account any of the walk on the left side of the road, as shown on the typical sections. The quantity should be substantially higher.

Question Submitted: 3/8/2006

Question Number: 4

Please specify how wrought iron fencing is to be attached to Allen block, how is the post secured? Will the wall cap be cored? will the blocks need to be grouted solid to secure the post?

Proposed details for attachment of wrought iron fence to the top of the retaining wall is shown on ITEM SPECIAL, MISC.: WROUGHT IRON FENCE DETAIL on Sheet 33 as revised by Addendum No. 1

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.