

Ohio Department of Transportation

Prebid Questions

Project No. 080287

Sale Date - 5/7/2008

Question Submitted: 4/17/2008

Question Number: 1

The details and plan note on pages 6 and 68 do not state what type of material is to be used for replacement of ref # 19 Pavement repair, as per plan. Could you clarify what type of asphalt is to be used for the replacement in the pavement repair areas. The typical referred to on page 68 only show the proposed pavement section. Since this area gets milled, is the plan intent to put surface in the patch then mill it off? Also, the detail on page 68 refers to the typical sections for existing depth of the pavement. The typical does not state a depth for the existing asphalt. Can the depth of the existing asphalt be provided since the pavement repair item is bid by the square yard.

A1) The pavement repair area is to use the same material type and build-up as shown in the Typical Sections for the proposed widening areas. A2) Yes. A3) The depth of the repair is to be the same depth as shown in the Typical Sections for the proposed widening areas. Note that the bottom of the repair area does not need to match the bottom of the existing pavement.

Question Submitted: 4/23/2008

Question Number: 2

Is the existing gas line on the west side of SR 4 between STA 82+00 and 74+00 to be relocated prior to the start of work? If not is it possible to compact granular material around the gas line after the excavation of the soft subgrade as required?

The existing gas line on the west side of SR 4 between STA 82+00 and 74+00 is to be relocated by Duke Energy prior to the start of work.

Question Submitted: 4/23/2008

Question Number: 3

The Maintenance of Traffic cross sections on sheet 11 show lane closures for Phases 3B, 3C, 4A, 4B and 5. Are the lanes that are shown to be closed on this sheet required to be reopened for traffic from 6:00am to 8:00pm as the note indicates on sheet 9 or does the note refer to all lanes shown to be open on the MOT cross sections?

Yes, the note on sheet 9 applies to the referenced phases on sheet 11.

Question Submitted: 5/1/2008

Question Number: 4

Station 68 Entrance to LaQuinta Properties page 18 calling for curb ramps, are there any? Also at Crescentville Road is there curb ramp at Southeast corner?

Question Submitted: 5/2/2008

Question Number: 5

Plan Note for Ornamental Fence on page 93 refers to "See Special Provisions". Where or what are these provisions? Please clarify. Thank You

Attached to the back of the plans

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.