

# Ohio Department of Transportation

## Prebid Questions

Project No. 040637

Sale Date - 12/15/2004

Question Submitted: 12/9/2004

Question Number: 1

Is it appropriate to have a smoothness specification for a one inch mill with a one and one half inch overlay? Should there be a leveling course?

**Yes, it is appropriate. This is an optional incentive for the contractor. There are no disincentive. There is no need for the leveling course since there is a mill procedure.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.