

Ohio Department of Transportation

Prebid Questions

Project No. 060280

Sale Date - 6/21/2006

Question Submitted: 6/9/2006

Question Number: 1

1. Please clarify the expectation of the material type to be used for Item 252 APP.

Standard item 252 references the use of both a 301 and a 448 Type 2 material. Sheet 2/9 references the use of a 448 Type 2 with a PG 70-22M. It does not reference using a 301 or 302 and it does not address lift thickness, etc. Is it truly ODOT's intent to stack up 10" of Type 2 during a night-time lane closure and open it to traffic in the morning as detailed in the permitted lane closure web site?

2. Please clarify ODOT's expectation with regard to how rutting of the patches will be handled.

Assuming the existing 403 remains in place when the 10" slabs are removed, the contractor will have a total of 10" of freshly placed hot-mix to open to heavy truck traffic each morning. As specified, we believe the MOT restrictions do not allow for an adequate time for the mix to cool, and we expect some/all of the patches to rut. Will ODOT address this issue or will the contractor be liable for a difficult surface mill/fill of these small patches?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.