

Ohio Department of Transportation

Prebid Questions

Project No. 040586

Sale Date - 11/17/2004

Question Submitted: 11/10/2004

Question Number: 1

Page 8/86 of plans-

Left hand column CLOSURE OF US-50 states road may be closed 6:00pm on Friday and reopened 6:00am Monday.

Right hand column CONSTRUCTION NOISE states no work 11:00pm to 6:00AM.

Does the Construction Noise note apply to the full closure Friday night to Monday morning?

yes

Question Submitted: 11/11/2004

Question Number: 2

Sheet 26/66 in the profile shows a 12" high pressure water main owned by Clermont County and a 6" welded gas main that will be over the proposed 54" Type A culvert. The profile shows several bends in the utilities. When the existing utilities are exposed to remove and replace the culvert, there is a good possibility that they will blow apart under their own pressure.

Is the contractor to include the cost to relocate the utilities in his bid? If so, will more right of way be necessary to install the run around of the existing utilities?

The utilities will remain in place. It will be the contractors responsibility to protect these utilities during the replacement of this conduit. The contractor shall include any cost to protect these utilities into their bid.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.