

Ohio Department of Transportation

Prebid Questions

Project No. 050060

Sale Date - 1/26/2005

Question Submitted: 1/18/2005

Question Number: 1

How deep is the planing, ref. 0012, to be on this project?

On sheet 2 of the plans under Item 254 Pavement Planing, Asphalt Concrete, from station 7+00 to 30+75 the depth is 3 inches and from station 30+75 to 49+25 the depth is 2 inches.

Question Submitted: 1/20/2005

Question Number: 2

Reference 6 2A Curb, Typical shows curb Type 6 of curb & gutter, if it is 2A does it have to be doweled to something or is it actually Type 6?

Reference 5 do curb ramps have truncated domes?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.