Ohio Department of Transportation Prebid Questions

Project No. 098026 Sale Date - 7/15/2009

Question Submitted: 6/25/2009

Will the State allow the grinding slurry to be disposed of on State Property (old rest area)

The contractor's request below is denied. Disposal of waste material (grinding slurry) is not allowed within Project Right-of-Way or on any other Department-owned property. See CMS 107.11.A.

Question Submitted: 7/13/2009

Question Number: 2

Question Number: 1

According to 3M installation guideline for their preformed tape they have established a cut off date of September 15th, however the project completion date is NOT until October 31, 2009.Due to this conflict, we believe there is NO way that this project can be complete this year. Can the department extend the completion for the striping until June 2010. We know of NO pavement marking contractors that would be willing to warranty the pavement markings that are installed outside the manufacture cut off date for installation.

The manufacturer's specifications allow for placement at air and surface temperatures down to 40 degrees after the cut-off date.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.