

Ohio Department of Transportation

Prebid Questions

Project No. 091086

Sale Date - 7/29/2009

Question Submitted:

Question Number: 1

There is a 96" dia culvert type A called out that is listed only as 706.02. Why is this? Or are all type A culvert material acceptable?

Only 706.02 conduit is allowed at this location. The required size of alternate material conduits would not fit the site due to lack of cover. Please bid the project as shown in the plans. No addendum is needed.

Question Submitted:

Question Number: 2

There is a 96" dia culvert type A called out that is listed only as 706.02. Why is this? Or are all type A culvert material acceptable?

Only 706.02 conduit is allowed at this location. The required size of alternate material conduits would not fit the site due to lack of cover. Please bid the project as shown in the plans. No addendum is needed.

Question Submitted: 7/23/2009

Question Number: 3

Will 4 ARRA Signs be required on this project to cover both SR 124 & SR 350? Or will 2 Signs be sufficient?

Sheet 3 of the plans states to supply 4 signs for the project. This would consist of 2 signs for each location.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.