

# Ohio Department of Transportation

## Prebid Questions

Project No. 080464

Sale Date - 7/23/2008

Question Submitted: 7/16/2008

Question Number: 1

The Proposal calls for "special bollards", no description is provided, please clarify.

**"Special" is simply in the description of the 690 standard item. The bollards should be constructed according to SCD RM-5.1 as indicated on the Title Sheet.**

Question Submitted: 7/17/2008

Question Number: 2

Our prior question regarding special bollards was addressed with SCD RM-5.1 which specifies Steel bollards. However, this standard pertains to round or square, removable or permanent bollards, which type or types are required?

**The shape of the bollards can be round or square. The placement of the bollards is indicated in the standard drawing. The two on the outsides are permanent and the inside is removable.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.