

# Ohio Department of Transportation

## Prebid Questions

Project No. 100086

Sale Date - 2/25/2010

Question Submitted: 1/20/2010

Question Number: 1

On page 5 of the plans, in the ITEM 614-MAINTAINING TRAFFIC (WORK ZONE MARKINGS) there is mention of fog seal on the project. If it is ODOT's intent to have fog seal on the project, could an addendum be issued containing the fog seal liquid type, wait time between chip seal and fog seal, and wait time between fog seal and permanent striping.

**No fog seal is required for this project.**

Question Submitted: 2/23/2010

Question Number: 2

Is it ODOT's intent for the Raised Pavement Markers to be covered before the application of the 422 Single Chip Seal? This process has been performed in other districts (district 9) and has proven to reduce the reflectivity of the RPM's.

**Yes As per CMS 422.09-Paragraph 10: States the following: "Protect all utility castings, monument boxes and other similar items using tarpaper or other approved material. Remove protection before sweeping and opening to traffic."**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.