

# Ohio Department of Transportation

## Prebid Questions

Project No. 090522

Sale Date - 12/4/2009

Question Submitted: 11/16/2009

Question Number: 1

bid item 24 curb markings 560 feet. Curb markings can not be performed with thermoplastic. This bid item needs to be changed to another material or deleted altogether.

**Thermoplastic curb marking bid item deleted and replaced with fast dry bid item. See addendum number 1.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.