

# Ohio Department of Transportation

## Prebid Questions

Project No. 070342

Sale Date - 6/27/2007

Question Submitted: 6/19/2007

Question Number: 1

On page 5 of the plans, Item 614, Maintaining Traffic (lanes open during holidays or special events), the straight line miles indicated are not within the work limits of the plans. QUESTION: Are the straight line miles correct?

Question Submitted: 6/21/2007

Question Number: 2

The project is set up to place a single lift of 424 Fine Graded Polymer Asphalt, Type B material over existing pavement which has been crack sealed. By plan, the new 448 density specification is being implemented on this project. QUESTION: Due to the varying conditions of the existing pavement, the placement of the proposed pavement will be variable depth, should the new 448 density specification apply?

**Yes, 448 density specification will apply.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.