

Ohio Department of Transportation

Prebid Questions

Project No. 070131

Sale Date - 3/7/2007

Question Submitted: 2/26/2007

Question Number: 1

A product is specified for the High Density Polyurethane on Drawing 8 of 22 that has a density of 3 lbs/cf and a strength of 40 psi. The highest density and strengths of products that I can find are 2.8 lbs/cf and 37 psi. Does ODOT know of a product name or manufacturer that can meet the specification?

Listed below are a few polyurethane manufacturers. Note that this is not an all inclusive list as there are other manufacturers that can meet the specification requirement as well. Geotech Services, Inc. 25205 Broadway Avenue Cleveland, OH 44146 Telephone: 1-800-875-5826; Green Mountain International, LLC 235 Pigeon Street Waynesville, NC 28786 Telephone: 1-800-942-5151; Uretek (Indiana and Ohio Division) 1625 N. Whitcomb Ave. Indianapolis, IN 46224 Telephone: 888-248-6868

Question Submitted: 3/5/2007

Question Number: 2

Is it possible to get the existing structure drawings online for HAM-50-2142L and HAM-275-2123?

<ftp://ftp.dot.state.oh.us/Pub/Contracts/Plans/070131/>

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.