

Ohio Department of Transportation

Prebid Questions

Project No. 060188

Sale Date - 4/5/2006

Question Submitted: 3/23/2006

Question Number: 1

I noticed there is a Ref. 85 pertaining to RR insurance but when going thru the proposal I didn't find any information regarding railroads. This information is needed for our bonding company.

Please forward any info necessary.

Thank you,

Maureen Russo

Question Submitted: 4/4/2006

Question Number: 2

this job involves steel work on 15 bridges. one bridge is a RR bridge. it has a plan note that the existing paint must be removed from the faying surfaces. we assume the note applies to that bridge only. please confirm. thank you

ANSWER: On project D12-BH-FY2006, existing paint must be removed from the faying surfaces at each location. The note included on sheet 44 of 52, Item 513 - Structural Steel, Misc: Floorbeam Retrofit, applies specifically to the CSX Railroad bridge (Lak-2-4.56). However, Section 513.20B of the CMS apply to all structures.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.