

Ohio Department of Transportation Prebid Questions

Project No. 100428

Sale Date - 7/15/2010

Question Submitted: 6/28/2010 10:51:00

Question Number: 1

Please add a line item for 1 each signal support foundation (to be used with item 0090)

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

Ohio Department of Transportation - Prebid Questions

Project No. 100428

DEF-84435 - SR-66-4.69

Sale Date - 7/15/2010

Question Submitted: 7/14/2010 4:42:24 PM

I think there should be an item for removing the existing signal installation

No signal currently exists at this location. No addenda is required.

Question Submitted: 7/12/2010 4:44:02 PM

What width are the steps on page 13? How many risers will be replaced?

The entire existing steps need to be removed. The replacement will be as defined in SCD RM-2.1 (Type A). The width of the steps is 3' as per the SCD and the design parameters are variable for the risers, within a range, so it is up to the contractor to decide the best layout for the elevation change. Plans estimated a length to be 15'. The contractor is designing the steps as per the SCD. No addenda is required

Question Submitted: 7/9/2010 4:14:32 PM

Can the office calcs be made available for this project?

Question Submitted: 7/6/2010 9:33:09 AM

With the addition of Ref.200 in Addenda 4 are you going to delete ref. 56 foundation that was originly set up for this job?

See addendum 5

Question Submitted: 6/28/2010 10:51:15 AM

Please add a line item for 1 each signal support foundation (to be used with item 0090)

See addendum 4