

Ohio Department of Transportation Prebid Questions

Project No. 080108

Sale Date - 2/13/2008

Question Submitted: 2/1/2008

Question Number: 1

Could you provide more details on the temporary approach slab widening as shown on sheets 18 and 19? Should this be changed to pavement for maintaining traffic? During Phase One A and Phase One B (sheets 18-21) portions of the existing guardrail confli

A. Intent is to place flexible pavement in these two areas. Quantities of Item 410 - Traffic Compacted Surface, Type A or B and Item 614 - Asphalt Concrete For Maintaining Traffic have been provided in the plan and may be used for this purpose. A. Inten

Question Submitted: 2/1/2008

Question Number: 2

Will Stay-in-Place forms be allowed on this project?

No

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.