

Ohio Department of Transportation

Prebid Questions

Project No. 050247

Sale Date - 4/20/2005

Question Submitted: 3/18/2005

Question Number: 1

Line item 38 - Sawing & sealing asphalt concrete pavement joints has a quantity of 3,247 LF and on page 13/43 the plans indicate the limits within which this item will be used but in no place do the plans indicate where the saw & sealing is specifically to be used. I assume that the intent is to saw & seal the pavement joint that is created when the existing pavement is full depth cut and a joint is created between the new 2' wide asphalt and the existing pavement. Please confirm that this is correct or identify the intended location of the sawing & sealing.

This is correct, the intent of the plans is to saw and seal the full depth joint between the existing pavement and the proposed pavement. The station limits on sheet 13, for this item of work, indicate the same station limits as shown on the Typical Sections. I feel that an addendum is not necessary, since the quantity is correct and it is fairly obvious where the sawing and sealing will occur.

Question Submitted: 4/7/2005

Question Number: 2

Bid item 451 6" Rein. Conc. Pav't, APP 1201 SY

This Quantity is actually in Square feet not Square yards.

so the bid quantity should be 134 SY

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

Ohio Department of Transportation

Prebid Questions

Project No. 050013

Sale Date - 1/12/2005

Question Submitted: 1/10/2005

Question Number: 1

1) What is the type of brick pavers to be used on the project?

2) Do the existing trees get removed, or is the contractor to work around them. Plans do not call for removal of existing trees however on the new construction plan view the trees are not addressed.

Please respond to these questions asap with an addendum.

Sincerely,

Christopher A. Batdorff
Columbus Asphalt Paving, Inc.
Vice President

Question Submitted: 1/5/2005

Question Number: 2

On plan sheet 3 it shows the typical section No. 1. It calls for 4" concrete walk to be placed between the bricks and the mezzanine wall. The problem is, it shows it as being at least 8" thick, but the legend still calls for 4". Please clarify.

The typical section is not drawn to scale. The walk to be placed between the bricks and the mezzanine wall is to be 4" thick, as indicated by the legend on sheet 3 of the plan.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.