

Ohio Department of Transportation

Prebid Questions

Project No. 100337

Sale Date - 6/3/2010

Question Submitted: 5/20/2010

Question Number: 1

1) Is there anyway to better define the locations of the pavement repairs, in order to properly price the traffic control.(need to know how many lanes to close for the repairs)

See addendum 1

Question Submitted: 5/24/2010

Question Number: 2

Due to the high risk nature of Item #5 (Full Depth Removal and Rigid Replacement), with the limited lane closures and/or weekend work and the potential for \$12,000/hr in liquidated damages we must know the lane and station of each repair.

We provided the information we had to the contractors via the addendum sent down last Friday (with the tables showing the repair areas). The Contractors will need to base there bids upon this information.

Question Submitted: 5/25/2010

Question Number: 3

There is a large bust in the quantity of 255 Full Depth Pavement Sawing. On sheet 16/20, it appears that the calculation of sawing was done using twice the product of length times width as opposed to twice the sum of length plus width. The quantities are actually twice the area of the repair in SF, as opposed to a LF around the perimeter.

Question Submitted: 5/25/2010

Question Number: 4

On page 8 of 20 the last line of each of the striping items states" that the striping needs to be performed in conjunction with the partial depth repair and completed the same day. That would be very expensive and unneeded since you have work zone markings set up. Can that sentence be removed since it contradics all the work zone notes on 14 of 20?

Question Submitted: 5/25/2010

Question Number: 5

Plan sheet 12/20 shows maintenance of traffic notes for Fra-270-17.10-26.72 butt I dont see any quanities ste up for this area.

If there is no work shown in an area of maintenance of traffic, then that area can be ignored for bidding purposes. No addendum is needed.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.