

# Ohio Department of Transportation

## Prebid Questions

Project No. 090294

Sale Date - 6/3/2009

Question Submitted: 5/29/2009

Question Number: 1

Need clarification: Plans page 2/42, Item #881, Last sentence states "All existing thermoplastic pavement markings shall be removed prior to microsurfacing applications." Is paint which will not interfere with warranty micro surface to be removed per ODOT #421.08? On bid sheet Work Zone Markings are set up as Class III. Class III is not necessary on Union 31, Madison 323, and Fayette 62 due to paint going back as permanent. Use of Class III will require a full blown striping crew to mobilize each day for this temp. If Class II is used micro-surfacing contractor can apply at substantial cost savings to ODOT.

**Pavement markings shall be removed per 881.04 A. No change to the plans will be made.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.