

Ohio Department of Transportation

Prebid Questions

Project No. 100290

Sale Date - 5/20/2010

Question Submitted: 5/12/2010

Question Number: 1

ODOT Project 290(10) FRA/DEL SR-33/257 – Note on page 10/65 under Urban Paving Area “All planed pavement shall be resurfaced with 1.5” of the asphalt concrete surface within the same day”, is in conflict with the notes on page 7/65 “All planed pavement shall be resurfaced with 1.5” of the asphalt concrete surface course within 5 consecutive days”. Please clarify.

Ignore the last paragraph of the URBAN PAVING AREA note on plan sheet 10/65 stating: “All planed pavement shall be resurfaced with 1.5” of the asphalt concrete surface course within 5 consecutive days”. The plan note titled ITEM 254 PAVEMENT PLANING, ASPHALT CONCRETE on plan sheet 7/65 shall take precedence which states: “All planed pavement shall be resurfaced with 1.5” of the asphalt concrete surface course within 5 consecutive days”.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.