

Ohio Department of Transportation Prebid Questions

Project No. 090537

Sale Date - 12/17/2009

Question Submitted: 12/10/2009

Question Number: 1

With a job of this size and spring temperatures of an average of 47.60 degrees in April and needing a 50 degree start temperature can the interim completion date be moved back 30-45 days?

ODOT feels that the work can be completed by the interim completion date. Therefore the interim date will not be moved.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.