

Ohio Department of Transportation

Prebid Questions

Project No. 090541

Sale Date - 12/17/2009

Question Submitted: 12/11/2009

Question Number: 1

Sheets #70, #77, #85 state that "removal of unsuitable material and replacement with compacted bedding material, included with item 503, unclassified excavation ... depth to be 2.5' is assumed for establishing quantity" -- Question: - the compacted bedding material to replace the unsuitable material needs to meet what specification (ie. if granular material, what type)?

Elliptical pipe shall use type 2 bedding as per 603.6 of the C&MS and Concrete boxes shall use type 1 bedding as per 603.6 of the C&MS. Elliptical pipe shall use type 2 bedding as per 603.6 of the C&MS and Concrete boxes shall use type 1 bedding as per 603.6 of the C&MS.

Question Submitted: 12/2/2009

Question Number: 2

Bid items 32 and 33 Edge line and Center line. On sheets 18 thru 27 the quantities for these items were counted twice for the same areas. The quantities should be halved.

See addendum

Question Submitted: 12/7/2009

Question Number: 3

Are structural drawings available for existing structures at 10.53, 10.77, and 10.88?

<ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/GAL-25312/>

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.