

# Ohio Department of Transportation

## Prebid Questions

Project No. 090067

Sale Date - 1/28/2009

Question Submitted: 2/16/2009

Question Number: 1

The plans indicate that 424-B Asphalt Surface course is to be placed on the intersection areas. Would the Dept. consider changing the intersection area surface course to a 448-1 as it is much easier to work with for this kind of application. Please respond via addendum if any response is made so all bidding contractors are aware.

Question Submitted: 2/16/2009

Question Number: 2

Are concrete Tee's required to make the connection into the 24" conduit with the 15" and 24" coming in from the East.

**Concrete pipe tee's are required in order to make the connection into the 24" conduit at Taylor May Rd. Please bid accordingly..**

Question Submitted: 2/16/2009

Question Number: 3

In response to the concrete Tee's that are required could you answer this question by Addendum so they become a part of the bid documents.thank you,

**Please direct the Contractor to 603.14. It states that the Department will measure conduit by the number of feet, measured from center-to-center of appurtenant small structures or between open ends inclusive of lengths of pipe bends and branches.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.