

Ohio Department of Transportation

Prebid Questions

Project No. 060208

Sale Date - 4/19/2006

Question Submitted: 4/12/2006

Question Number: 1

Can the 2" deep recess at the joint between the approach slab and bridge deck for the Polymer Modified Asphalt Expansion Joint System be formed with the forms left in place until the joint system is installed instead of being milled?

The Polymer Modified Asphalt Expansion Joint must be constructed to the dimensions shown on the plan. This can be done by milling or forming the joint into the deck.

Question Submitted: 4/12/2006

Question Number: 2

Sheet 23/27 shows 2' porous backfill behind the new abutment concrete. Under which item will this be paid?

Question Submitted: 4/13/2006

Question Number: 3

Can the completion date for this project be extended?

The current interim completion date of Aug. 31 only allows about 7 weeks per phase.

The District has reviewed your request and respectfully declines.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.