

Ohio Department of Transportation

Prebid Questions

Project No. 100340

Sale Date - 5/27/2010

Question Submitted: 5/20/2010

Question Number: 1

On page 5 of the plans, the Mow Strip note indicates that "the mow strip shall be integral to the socketed concrete foundation". We request a clarification to allow for the placement of sleeves in the concrete mow strip that the socketed concrete post foundations could be subsequently placed in.

Question Submitted: 5/21/2010

Question Number: 2

Plan Sheet 5 Item Special - Mow Strip If per the manufacturer's recommendation or if the manufacturer has no issue with constructing the concrete mow strip separate from the post foundation [not integral with], will this be permitted. Obviously the asphalt mow strip is not constructed integrally with the foundation. This will permit more accurate post/sleeve socket alignment.

ODOT would permit this. Expansion material would need to be used between the foundation and the Mow Strip at each location.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.