

Ohio Department of Transportation

Prebid Questions

Project No. 070217

Sale Date - 5/4/2007

Question Submitted: 4/23/2007

Question Number: 1

A question for clarification. Sheet 3/16 note (Excavation) states "Excavated material shall not be wasted nor stockpiled within the project limits." Sheet 3/16 note (Contractor's use of ODOT Right-of-Way) "The old rest area located approximately 500 feet east of the project has been designated as an approved location for the contractor to use for the purpose of storing equipment and materials." The old rest area is not considered part of the project limits, so therefore, may be used to store excavated materials from the project?

Question Submitted: 4/30/2007

Question Number: 2

Bid Item 31 description of item does not match the plan. Plan sht.#9 notes that the 42" pipe is to be 8 gage and shop elongated. The description of item 31 does not match these requirements. Please advise.

Question Submitted: 5/3/2007

Question Number: 3

On sheet 2/16, the following materials are specified: Legend #4: Item 203 Granular Material, Type E, Using #8 Coarse Aggregate Legend #3: Item 690 Geotextile Fabric, 712.09, Type A In the Construction and Materials Specifications, Section 203.03, I, the paragraph states the following: "If Granular Material Type E in 703.16C is allowed or specified, use a geotextile fabric conforming to 712.09, Type D or Granular Material Type B, C, or D on the top, bottom, and around the Type E material to prevent piping of the material into the Type E material." Is Type D Geotextile Fabric required in addition to the bid quantity for Type A Geotextile Fabric or are additional granular materials required according to the specification to prevent piping?

No Type D geotextile fabric or Granular material Type B, C, or D is required. Use 712.09, Type A.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.