

Ohio Department of Transportation

Prebid Questions

Project No. 078013

Sale Date - 7/18/2007

Question Submitted: 7/10/2007

Question Number: 1

170 controllers are specified. Timing charts and coord programs are shown but there isn't any reference to the supply of software. This project will be maintained by other than ODOT forces which eliminates the use of ODOT supplied firmware. What do we supply for the 170 controllers to have them operate as per plan?

The spec. book states that the controller software be supplied with the controller units. We didn't specify a controller software so that the bid would be generic. The bidder/manufacturer should supply whatever software they have to operate the 170 controllers as shown in the plans.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

Ohio Department of Transportation

Prebid Questions

Project No. 070270

Sale Date - 6/1/2007

Question Submitted: 5/22/2007

Question Number: 1

B/R# 22 asks for Pedestrian Signal A2 which is usually a 2 Section 12". Plan Page 8/13 Shows them as 1 Section. Do they want a D2 = 16" Housing with LED or a 1 Section 12" with Combo LED or 2 Section 12" with LED's?

We want the A2 which are 2 section with 12" LEDs according to the pay item.

Question Submitted: 5/25/2007

Question Number: 2

Item 40: Controller Unit, Type 170E with Cabinet Type 332, as per plan. The specifications for this item requires software to be included with the controller (see ODOT 2005 CMS 733.02.B). Software, unless provided by the maintaining agency is to be included with the controller. There is only 1 supplier in the state of Ohio that has access to software for the Type 170E controller, thus making this item sole-source and proprietary.

The Department respectfully disagrees that having only one Ohio supplier makes the item proprietary or sole-source.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.