

# Ohio Department of Transportation

## Prebid Questions

Project No. 080218

Sale Date - 3/26/2008

Question Submitted: 3/15/2008

Question Number: 1

Under the Linear Delineation note on plan sheet 3, there is no note indicating the spacing of the delineation panels. Are the panels intended to be continuous?

**Linear Delineation is intended to be continuous, hence there is no spacing**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

# Ohio Department of Transportation

## Prebid Questions

Project No. 070394

Sale Date - 8/15/2007

Question Submitted: 8/10/2007

Question Number: 1

1. Reference is made to the linear delineation reflectorization, as per plan.a. Does ODOT want the 4 inch or 6 inch delineation material?b. What color does ODOT want? 3M makes their material in four colors and the price difference between the colors is significantc. Does ODOT want the delineation continuous? If not, what is the spacing between panels?2. Reference is made to the bollards, vinyl type material.a. Since the plans do not specify a manufacturer or model and since the description of the material desired is not very specific, is a 36 inch surface mounted delineator as manufactured by Bunzyl or Impact Recovery acceptable? These materials are on the ODOT approved materials list

**1.a. We want 6 inch. 1.b. We want white. 1.c. We want continuous. 2.a. 36 inch delineators are acceptable.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.