

Ohio Department of Transportation

Prebid Questions

Project No. 060303

Sale Date - 6/21/2006

Question Submitted: 6/14/2006

Question Number: 1

Ref # 049 - 120" CONDUIT, TYPE A 706.02

CAN 97"x151" CONDUIT, TYPE A 706.04 BE USED AS A SUBSTITUTE? THIS IS THE HORIZONTAL ELLIPTICAL EQUIVALENT SIZE. DESIGN COVER WOULD INCREASE FROM 9.25' TO 11.08' AND WOULD BE ACCOUNTED FOR.

The pipe that is specified in the plans is adequate and the district does not wish to issue an addendum for this request and the pipe should be bid as is. The contractor has the ability through the VECP proposal note to submit this request if it truly is a cost savings to the department.

Question Submitted: 6/14/2006

Question Number: 2

Typical sections on plan sheets 3/82 through 6/82 as well as various cross sections show only one location (HAN-224-0550) to be benched into existing slope prior to placement of embankment. Will benching of slopes be required as stated in 2005 CMS 203.05, for all slopes greater than 8:1, even though no benching is shown on the plans?

As stated on the title sheet, the plans are to be constructed in accordance with the 2002 CMS, including the required benching for embankment as per 203.05. The additional benching requirements for Culvert Han-224-0550 are shown on the typical section (sht 5) and the cross sections (shts 18 and 19).

Question Submitted: 6/14/2006

Question Number: 3

On page 24, Proposal Note 124, Contract Time, states...The date for the beginning of the contract time will be the date traffic is restricted but no later than June 1, 2006. With a bid date of June 21st, what date should this be?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

Ohio Department of Transportation

Prebid Questions

Project No. 050489

Sale Date - 9/21/2005

Question Submitted: 9/13/2005

Question Number: 1

On the title sheet p.1/82 and again on pgs. 15/82 & 16/82, the plans state in the project description for culverts #2 (HAN-224-0579) and #5 (HAN-224-0721), "Purchase Right of Way for Clear Zone Grading." Is this the contractor's responsibility or has this R.O.W already been acquired?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.