

Ohio Department of Transportation

Prebid Questions

Project No. 098013

Sale Date - 4/15/2009

Question Submitted: 10/14/2008

Question Number: 1

All the intersection in downtown Kenton has existing curb and gutter. Will there be a curb and gutter removed and replacement items added?

The existing curb and gutter is to be saw cut at the face of the existing curb as shown in the " Section A-A Existing Walk Detail" on sheet 3 of Std. Dwg. BP-7.1. The saw cut is incidental to the cost of removing the existing curb as per sections 202.05 of the C&MS. The plans include a quantity to remove the existing curb at the location of new curb ramps. There is no need to add curb and gutter removed and replacement items, so no addendum is required.

Question Submitted: 10/14/2008

Question Number: 2

Proposal calls for design requirements for plant mix pavements to be (medium). But the bid item for Reference number 9 calls for Asphalt Concrete Surface Course, Type 1H. There are other mixes on this project, so what does ODOT want?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.