

# Ohio Department of Transportation Prebid Questions

Project No. 091002

Sale Date - 6/3/2009

Question Submitted: 4/1/2010

Question Number: 1

Reference #97 Portable Concrete Barrier, 50". The department has specified 50" barrier for this project. Can the contractor use 32" barrier with a glare screen to achieve the 50" height that is being requested?

**No, the 50" height specified must be used. The height of the PCB is required for protection to motorist from potential falling rock during the work in the rock fall area. Glare screen will not provide the added protection required.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.