

# Ohio Department of Transportation

## Prebid Questions

Project No. 100059

Sale Date - 2/4/2010

Question Submitted: 1/8/2010

Question Number: 1

Proposal Ref # 18 calls out 9.5mm intermediate course, as per plan; plan sheet 2/23, legend item 6 calls out 19mm intermediate, as per plan; plan sheet 3/23, top center of page general note Item 442, Asphalt Concrete Intermediate Course, As Per Plan calls out 19mm PG70-22; plan sheet 5/23, general summary calls out 9.5mm intermediate, as per plan. Should the asphalt intermediate course be 9.5 mm or 19mm?

**The Typical and Plan Note are correct, the Bid Item has been revised to ASPHALT CONCRETE INTERMEDIATE COURSE, 19MM, TYPE A(448), AS PER PLAN. The revisions are in addendum 1. The Typical and Plan Note are correct, the Bid Item has been revised to ASPHALT CONCRETE INTERMEDIATE COURSE, 19MM, TYPE A(448), AS PER PLAN. The revisions are in addendum 1.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.