

# Ohio Department of Transportation

## Prebid Questions

Project No. 060523

Sale Date - 12/13/2006

Question Submitted: 11/20/2006

Question Number: 1

Can the existing plans for these structures be made available via the internet?

**Available at <ftp://ftp.dot.state.oh.us/Pub/Contracts/Plans/060523/>**

Question Submitted: 12/7/2006

Question Number: 2

1. Is any of the temp pavement being left in place as permanent pavement?  
2. Plan sheet 9/67 states that the steel portion of the ODOT-designed centerline shoring will be left in place. It also states that the contractor can design his own system. If we do, will we be required to leave the steel portion in place?  
3. We don't see a requirement to work on only one bridge at a time. Can we maintain traffic with 1-lane closure on both structures simultaneously?  
4. You provided the existing plans for only one of the two structures. Can we also get a copy for the second posted on the internet?

**1. None of the temporary pavement is being left in place as permanent pavement. 2. If contractor chooses to design his own shoring, he would not have to leave steel unless he felt it necessary for MOT. 3. Traffic can be maintained with one lane closure on both structures simultaneously. 4. Existing plans for the HOC-327-1.01 bridge are now at <ftp://ftp.dot.state.oh.us/Pub/Contracts/Plans/060523/>**

Question Submitted: 12/7/2006

Question Number: 3

The temporary centerline shoring designs detailed in the drawings specify 3x8 and 4x8 southern pine material. Are these nominal dimensions or are they actual rough-sawn dimensions?

**The 3x8 and 4x8 are nominal sizes. The dressed size is 2.5x7.25 and 3.5x7.25.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.