

Ohio Department of Transportation

Prebid Questions

Project No. 103014

Sale Date - 6/3/2010

Question Submitted: 5/25/2010

Question Number: 1

Can you please clarify the intent of section 14.3 (Pavement) of the Scope of Services. Does the entire existing asphalt shoulder need to be replaced within the limits defined within the scope or can the existing shoulder be widened by sawcutting 12" into the edge of paved shoulder.

Answer will be part of Revised Addendum #1.

Question Submitted: 5/26/2010

Question Number: 2

Under section of 14.1 (Survey) of the Scope of Services, it indicates survey information is available on the District's FTP site. There is no survey information currently on the FTP site, could it please be added.

Survey information has been placed on FTP site. No addendum required.

Question Submitted: 6/1/2010

Question Number: 3

Scope of Services, section 13.2 calls for a minimum of 13' lane width to be maintained. Is this intended to be 11' from stripe-to-stripe, plus an additional 1' outside of each stripe to the toe of barrier/curb? If the intent is to be 13' stripe-to-stripe, then it appears that the new structure must be over-built in the 1st phase by 3' in width.

As stated in Addendum #1, Lane width specified in MOT Section 13.2 does not include barrier offset. No addendum required.

Question Submitted: 6/2/2010

Question Number: 4

As a follow-up to a previous question asked about the MOT lane width. Based on the existing bridge width and the proposed bridge width of 44', maintaining a distance of 15'(13'+1'+1') face to face of barrier during both stages of construction does not appear to be feasible. Is it the District's intent that the proposed bridge be overconstructed in width to accommodate the 13' lane width requirement during MOT?

It is District's intent to have 15' face to face of barrier during construction. Bridge width is a minimum of 44' face to face of guardrail. No addendum required.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.