

Ohio Department of Transportation

Prebid Questions

Project No. 050253

Sale Date - 4/20/2005

Question Submitted: 4/19/2005

Question Number: 1

PER 202.04, CONCRETE WATER LINE CONSTRUCTED BEFORE 1980 REQUIRES TESTING FOR ASBESTOS PRIOR TO REMOVAL. REF 2 - PIPE REMOVED 24" AND UNDER APPEARS TO INCLUDE AN ABANDONED WATERLINE. CAN ODOT PROVIDE INFORMATION ON TYPE AND YEAR OF CONSTRUCTION?

MUCH DEBRIS HAS BEEN DUMPED OVER THE SLOPES AND ALONG THE TOE OF EMBANKMENTS ON THE LEFT SIDE OF THE PROJECT. CAN THIS EXISTING MATERIAL REMAIN ON SITE? IF NOT, HOW WILL REMOVAL AND DISPOSAL BE PAID?

Question Submitted: 4/19/2005

Question Number: 2

PER 202.04, CONCRETE WATER LINE CONSTRUCTED BEFORE 1980 REQUIRES TESTING FOR ASBESTOS PRIOR TO REMOVAL. REF 2 - PIPE REMOVED 24" AND UNDER APPEARS TO INCLUDE AN ABANDONED WATERLINE. CAN ODOT PROVIDE INFORMATION ON TYPE AND YEAR OF CONSTRUCTION?

MUCH DEBRIS HAS BEEN DUMPED OVER THE SLOPES AND ALONG THE TOE OF EMBANKMENTS ON THE LEFT SIDE OF THE PROJECT. CAN THIS EXISTING MATERIAL REMAIN ON SITE? IF NOT, HOW WILL REMOVAL AND DISPOSAL BE PAID?

A1: The conduit is ductile iron constructed in the early 1990s. A2: The contractor did not state the nature of the debris. If the material is outside the construction limits, it can remain. If the material is inside the construction limits and is comprised of trees, stumps or vegetation, it will be removed as per Item 201, Clearing and Grubbing. If the material is inside the construction limits and it something other than trees, stumps or vegetation, it will be disposed of by the Jefferson County Engineer's forces.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.