

# Ohio Department of Transportation

## Prebid Questions

Project No. 068014

Sale Date - 11/1/2006

---

Question Submitted: 10/23/2006

Question Number: 1

The plan note for Clearing and Grubbing on Sheet 7 of the plans states "There are no trees or stumps marked for removal within the limits of the project".

A visit to the jobsite reveals that there are numerous trees and stumps that must be removed, along with approx. 2,000 feet of fence, before grading operations can begin.

If you want these removals to be part of the Clearing and Grubbing item, please consider correcting your general note to read "Remove all trees, stumps, and fence within the construction limits of the project".

Question Submitted: 10/23/2006

Question Number: 2

The quantity for Ref. No. 34, Item 407, Tack Coat, is overstated by a factor of 18.75. Our calculation of this item yields 225 gallons, the current plan quantity is 4,217 gallons.

---

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.