

Ohio Department of Transportation

Prebid Questions

Project No. 108030

Sale Date - 5/13/2010

Question Submitted: 5/3/2010

Question Number: 1

We are looking for a more detailed description of Item 690E13000 - SPECIAL - Rumble Strips (1,350 feet). Are they considered a full-lane rumble strip?

Answer: The detailed description of Item Special, Rumble Strips is located on sheet 52 of the plans. The Rumble Strips are to be placed across the 16' wide Ramp Lane. The Rumble Strips are 15' wide and placed as to not destroy either edge line.

Question Submitted: 5/5/2010

Question Number: 2

On page 15, Pavement Subsummary, subtotals that were carried to the general summary are incorrect. Please revise in an addendum.

An addendum will be issued with corrected totals.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.