

Ohio Department of Transportation

Prebid Questions

Project No. 080247

Sale Date - 4/9/2008

Question Submitted: 3/24/2008

Question Number: 1

Do to the substantial amount of structure related work and time frame in relation to the structure work on this project, would the department consider reducing the work performed by Prime contractor to 40%?

Question Submitted: 4/1/2008

Question Number: 2

Q) STR# 0804L/R, 0899L/R, 0912L/R, & 1048L/R - THERE ARE NO APP NOTES OR PAY ITEMS FOR DOWEL HOLES AT THE PROPOSED ABUTMENT (CLASS HP CONCRETE, SUBSTRUCTURE) LOCATIONS ON THE ABOVE STRUCTURES. PLEASE DEFINE HOW THE DOWEL HOLES ARE PAID.

Question Submitted: 4/2/2008

Question Number: 3

Can the existing bridge drawings be posted on the website?

<http://www.dot.state.oh.us/contract/ftp/attach/law-22985/>

Question Submitted: 4/3/2008

Question Number: 4

The plans state on sheet 16/280 state that the recycled asphalt pavement (RAP) from item 254 Pavement Planing is to be utilized in item 617 Shoulder Reconditioning, Misc as material to be placed under the guardrail. The suggested project phasing will not permit this to happen. Is it ODOT's intent to procure (RAP) from another source?

It is ODOT's intent to use the recycled asphalt pavement (RAP) from this project for Item 617 Shoulder Reconditioning, Misc to be placed under guardrail. The suggested phasing sequence noted on sheet 21/280 is for the structures, the guardrail work mentioned in these phasing paragraphs is limited to the railing attached to the structures. The intent was to have the proposed bridge terminal assemblies connect to the existing railing while the remaining bridge work was performed, the guardrail work mentioned is for the removal and construction of guardrail to permit this connection. The bulk of the guardrail work is to be constructed with the paving operations, which was intended in the second construction season of the project.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.