

# Ohio Department of Transportation

## Prebid Questions

Project No. 070512

Sale Date - 12/19/2007

Question Submitted: 11/13/2007

Question Number: 1

Page 18 of the plans-Typical Section. The top typical from 233+00 to 236+00 appears to have the placement of (7) 6" of 304 Aggregate Base going over top of (6) 6" of 301 Asphalt Base. Is this correct or are the items switched?

Question Submitted: 11/14/2007

Question Number: 2

Since there is not any signal work other than new loop detectors, why is the MAINTENANCE OF TRAFFIC SIGNAL/FLASHER INSTALLATION note (plan page 32) included in the plans? What intersections are to be included in this item? What new signal work is being done at these intersections? In the absence of any new signal work being done or any clarification to this note, we will assume that existing maintaining agency will continue to maintain the signals on this project.

**This project will not require any new signal work. The note on sheet 32 was added to provide guidance during the adjustment of the signal heads for the maintenance of traffic. This note shall apply to any existing traffic signal on US 40 that will require the contractor to adjust the signal heads to accommodate the new traffic patterns for the maintenance of traffic. The first paragraph of the general note on sheet 32 "Maintenance of Traffic Signal/Flasher Installation" will apply to this condition. At the time of signal head adjustment, the contractor will be responsible for any damage to any traffic signal component required to be handled during the modification of the signal system as stated in the general note on sheet 32.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.