

Ohio Department of Transportation

Prebid Questions

Project No. 101031

Sale Date - 3/11/2010

Question Submitted: 2/18/2010

Question Number: 1

Can the existing plans be made available?

Existing plans are available at <ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/LOG-19988/>

Question Submitted: 3/1/2010

Question Number: 2

Plan sheet 12/22 shows C6 x 10.5 sanitary sewer support channels. Is this a special pay item? If so which item/ref.?

See general summary plan sheet 7/39 sanitary sewer section which provides for item of pavement in the proposal as reference line 32 conduit, misc.: hanging pipe supports (including C6x10.5 sanitary sewer supports).

Question Submitted: 3/2/2010

Question Number: 3

Will stay-in-place bridge deck forms be allowed?

Stay-in-place bridge deck forms will not be allowed for this project.

Question Submitted: 3/3/2010

Question Number: 4

What is the anticipated completion date of the mussel relocation work listed on sheet 4? No instream work is allowed until this has been completed.

The mussel relocation work has been completed.

Question Submitted: 3/4/2010

Question Number: 5

Page 3/39 has a ITEM 201 Clearing and Grubbing note that states that there are no trees marked for removal, but plan sheet 10/39 shows trees marked for removal. Page 4/39 has the "Indiana Bat Note" that states that no "Bat Trees" may be removed between April 1 and September 30. With a sale date of March 11 the contractor will not have a contract by April 1. How can the "Indiana Bat Note" requirements be fulfilled?

The trees marked for removal are less than 12" in diameter, and are therefore brush. They were inspected and none of them are bat trees so the time restriction will not apply.

Question Submitted: 3/8/2010

Question Number: 6

What is the flow rate of the existing 8" sanitary sewer line?

The sewer line is owned by the Village. The maximum flow rate is 300,000 gallons per day, but it is currently flowing between 115,000 - 200,000 gallons per day.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.