

Ohio Department of Transportation

Prebid Questions

Project No. 091033

Sale Date - 6/10/2009

Question Submitted: 6/6/2009

Question Number: 1

On Page 20 of 30 Under Item 202 PORTIONS OF STRUCTURE REMOVED, OVER 20 FOOT SPAN, AS PER PLAN. The use of hoe ram's are not permitted to be used. May a contractor use a hoe ram since none of the existing structure is being saved or re-used.

District will consider a request from the contractor after the award.

Question Submitted: 6/6/2009

Question Number: 2

On page 21 of 30 under Temporary Shoring is the call out for the temporary sheeting of STA 254+12.91 1.0 RT., shouldn't it be STA 255+12.91 1.0 RT. ? What's in the plans would have the contractor driving sheeting toward's the pier and not the abutment where it is needed.

Thank you for pointing out this discrepancy in the bidding documents. The temp shoring should be STA 255+12.91, 1.0 RT. Because this is a relatively small matter relative to the entire project we will not delay the sale in order to process an addendum.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.