

Ohio Department of Transportation

Prebid Questions

Project No. 080338

Sale Date - 5/21/2008

Question Submitted: 5/16/2008

Question Number: 1

The Pavement Repair note on pg 3 states that repairs are to be completed after pavement planing and prior to placement of intermediate or surface asphalt courses. This is a Micro-surfacing project. There is no planing and no asphalt courses. It also states that repairs shall be made to a maximum depth of 8". There is an existing asphalt pavement surface with a 9" concrete base. Is it the department intent to do Partial Depth Repair in lieu of Pavement repair?

This is a standard note and you can ignore the planing and asphalt courses in the note since they obviously do not apply. The depth of the repairs will vary throughout. The maximum depth of 8" in the plan note is still valid.

Question Submitted: 5/19/2008

Question Number: 2

Is it the departments intent to complete 253 Pavement Repairs to the top of existing concrete base?

No, we are not limiting the depth of the repairs to the top of the concrete. The plan notes are correct and clear as to the intent of the pavement repair work.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.