

# Ohio Department of Transportation

## Prebid Questions

Project No. 100129

Sale Date - 3/18/2010

Question Submitted: 3/3/2010

Question Number: 1

Is it ODOT's intent to use the Supplemental Specification 800 dated 1/15/2010 - 401.15 that requires the use of Material Transfer Vehicles on this project for installation of 301, 19MM, 12.5MM including mainline and ramps?

**Yes**

Question Submitted: 3/3/2010

Question Number: 2

Do to the short lenght sections of the Single Slope, Concrete Barrier, Type D and the concrete footers required under each end section. Q-1 Would ODOT consider changing the asphalt footer to a concrete footer under the Type D Barrier. Q-2 Where is the Excavation paid for the Concrete Barrier End and Anchor Setions.

**A-1. Addenda number 1 will give the option to use concrete footer in lieu of asphalt footer under Type D barrier with no additional cost to State .A-2. cost of excavation under anchor and end sections is considered incidental to the cost of anchor and end section installations.**

Question Submitted: 3/4/2010

Question Number: 3

Can The Department provide existing drawings for bridge number LOR-90-1320R?

**Yes, existing structure drawings will be posted**

Question Submitted: 3/5/2010

Question Number: 4

Will the Department please clarify the note on page 19/67 of the plans. It states that, "Work permitted with driving lane closed as shown between 7:30 PM and 5:30 AM only." This was interpreted to mean that if the driving lane is left open, work can still be performed behind the Portable Concrete Barrier during daylight hours. Is this correct?

**No, Department's intent is to get this work done only at night time between hours of 7:30PM and 5:30AM while driving lane is closed.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.