

Ohio Department of Transportation

Prebid Questions

Project No. 090398

Sale Date - 7/29/2009

Question Submitted: 7/14/2009

Question Number: 1

Plans has set up Clearing and Grubbing on this project. Is it the intent of this item to include any defoliation on the pavement's edge where an asphalt overlay is specified, and will stripping be required in the areas designated for topsoil placement under the Linear Grading reference?

Question Submitted: 7/21/2009

Question Number: 2

1.) Since this is a Parks project that consists of Roadway, Parking Lots, and Camper Pads, does 448 Density apply to the project? 2) How will you view Liquid Binder Adjustment since GTR is specified? The GTR additive may not follow market trends of PG 70-22 liquid?

1. 448 density will not be required. 2. The PG 70-22-GTR will be tracked for bituminous price adjustment as PG 70-22.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.