

# Ohio Department of Transportation

## Prebid Questions

Project No. 092005

Sale Date - 11/5/2009

Question Submitted: 10/30/2009

Question Number: 1

Can we submit a paper bid and paper bid bond only. Do we have to submit a bid electronically?

**Yes, paper bids and paper bid bonds are acceptable on this project. All bidders should follow the bid submittal instructions listed in addendum #1**

Question Submitted: 10/30/2009

Question Number: 2

1. Close off top and bottom on channels?2. Double nut threaded rod?3. Paint channels? Prime?4. Conduits on exterior require 1 3/4" notch in channel?5. Are the roof patches expected to last 3 years?

**1. No, Not necessary2. No, not necessary. 3. No painting or prime is necessary.4. Yes, As indicated in the specification and notes, a maximum of one-inch notch is permitted where necessary to accommodate exterior conduits. 5. Yes, per the notes and specifications.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.