

# Ohio Department of Transportation

## Prebid Questions

Project No. 075003

Sale Date - 7/18/2007

Question Submitted: 7/17/2007

Question Number: 1

Please verify that 306.04 (Cement Treated Free Draining Base) is correct under the box culvert shown on plan page 10/15. It is shown as bedding under the culvert section.

**The reference to 306.04 on page 10/15 is a typo and should have read 603.04. The reference to 6" Type 1 Bedding is correct. The District wishes to continue the letting process without delay.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.