

Ohio Department of Transportation

Prebid Questions

Project No. 080380

Sale Date - 6/4/2008

Question Submitted: 5/30/2008

Question Number: 1

PROJECT CALL FOR THE NEW AGGREGATE REQUIREMENTS FOR 422 APPLICATION. STONE SUPPLIERS IN THIS STATE WILL NOT QUOTE THE AGGREGATE CAUSE THEY ARE SAYING THEY CAN NOT MEET THE 200 SIEVE AT 1.5. AGAIN IF WE BRING THIS STONE IN FROM OUT OF STATE, WITH BEING TRANSPORTED AND STOCKPILE IT IS NOT GOING TO MEET THE SPECS IN THE END RESULTS. CAN WE GO BACK TO THE OLD SPECIFICATIONS OF 200 SIEVE AT 2.0 ON THIS PROJECT?

The aggregate requirements mentioned in the pre-bid question do not apply to this project. The change in aggregate requirements mentioned are in SS 800-2008 and only apply to projects sold under the 2008 C&MS. This project uses the 2005 C&MS.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.